



Addendum # 2
May 15, 2007
HUNTER CREEK RIDGE PUMP STATION
Bid No. 04-119
Contract No. 0607-216

This addendum is to notify all potential bidders that changes have been made to the Bid Documents. This addendum **must be signed and returned with original bid documents.**

Response to Questions:

1. The Can Barrel shall be coated with a Protective Fusion-Bonded Epoxy Coating, interior and exterior, per AWWA C-213. The minimum interior thickness shall be 15 mils and the minimum exterior thickness shall be 12 mils.
2. Prior to coating, the surfaces to be epoxy coated shall be blast-cleaned conforming to SSPC SP10.
3. The exterior surfaces of the motor shall receive the manufacturer's standard primer and finish coating.
4. Certified performance tests for pump bowl assembly and motors shall be provided to TMWA, and shall be approved by TMWA's Project Manager prior to shipping by manufacturer.

All costs for Material, Equipment, and Labor required for these revisions shall be incorporated into appropriate bid items shown on the Bid Schedule.

End of Addendum #2

Firm Name _____