

Addendum No. 2
Glendale Pump Upgrade Project, Phase 2 –
Purchase of Sparks Zone AFD’s
Bid No. 0708-206
February 19, 2008

The following changes are made to the Bid Documents for this Project:

1. Revise the following paragraphs in Specification Section 26 19 23:
 - a. Paragraph 1.01.A.5, CHANGE to read: “Output Current: Minimum 130A full load at specified altitude and temperature.”
 - b. Paragraph 2.02.J.5, REPLACE with:
 - “5. Communication Interface:
 - a. Provide native to the AFD, or through a separate, internally mounted, module or converter.
 - b. MODBUS-TCP Ethernet communication capability.
 - c. RJ-45 Ethernet port.”
 - c. Paragraph 2.02.K, ADD the following:
 - “4. Communication Interface:
 - a. MODBUS-TCP Ethernet communication capability.
 - b. RJ-45 Ethernet port.”

(Note that the original section 2.02.K.4 was deleted in Addendum No. 1)

This addendum shall be signed and returned with the original Bid Documents.

Company Name: _____

Signature of Bidder: _____