

**ADDENDUM No. 1**  
**Anson, Bonneville, Harold & Penrose Drive Water Replacement**  
**for City of Reno 2009 Unit 3 Street Rehab.**  
**Contract No. 0809-065**  
**PWP # WA-2008-412**  
**August 18, 2008**

The following information is by reference incorporated into the bid document for the above referenced project. The bid dates and times remain the same.

1. Is the bid item for the 6" gate valve supposed to be the unit price for every gate valve on the project, or just one in particular?

Price each for all gate valves, except for gate valves noted in other Bid Schedule items, Technical Specs or Bid Item Clarifications.

2. The plans and details call for 42" of cover and the spec book calls for 36" of cover. Please clarify. 42" of cover is correct.
3. End of Technical Specifications, Section 02315, subsection 3.01.B, shall be changed to read:

"All backfill above the pipe zone shall be compacted throughout to minimum density of 90% relative density per ASTM D 1557 unless specified otherwise. See City of Reno conditions and project design for further requirements".

4. End of Technical Specifications, Section 02315, subsection 3.03.F, shall be changed to read:

"Densification and backfill in trenches will be installed in lifts of not more than 8 inches, and shall be densified, by mechanical means, to a relative compaction of 90 percent when tested in accordance with ASTM D 1557. See City of Reno conditions and project design for further requirements".

5. Revise Section 02315, all of subsection 2.02, to read as follows:

**2.02 Trench Backfill:**

A. Provide soil materials as described below free of debris, roots, wood, scrap material, vegetable matter, refuse, soft unsound particles, ice, or other deleterious and objectionable materials.

1. Water Main and TMWA Service Lateral Backfill:

Bring trenches to grade indicated on the Drawings. Use Type 2, Class B aggregate base material except around and up to 12 inches over water mains and service laterals where bedding shall be used. The material used above the bedding shall be imported crushed aggregate base meeting the following specifications:

Percent Passing	Sieve Size of Opening
100	1"
90-100	¾"
35-65	#4
15-40	#16
2-10	#200
Liquid Limit	35 Max
Plasticity Index per ASTM D4318	10 Max
R-Value:	70 Minimum

6. Revise Bid Item Clarifications, Item No. 20 Furnish & Place a Permanent Asphalt Concrete Pavement Patch; to read as follows:

Last sentence of paragraph 2 shall be deleted and replaced with the following: 'The patch thickness shall match existing but shall not be less than 4-inches in thickness or as required in the City of Reno Encroachment/Excavation Permit Special Conditions of Approval'.

End of Addendum #1