

Notice to Bidders THIS IS NOT AN ORDER

ADVERTISED BID #0708-206
RELEASE DATE: January 28, 2008

SEALED BIDS must be submitted to **TRUCKEE MEADOWS WATER AUTHORITY (TMWA)**, in person to 1355 Capital Blvd., Reno, NV 89502 or by mail to P.O. Box 30013, Reno, NV 89520-3013, by not later than 2:00 p.m. on February 26, 2008. Bids received after the date and time set for receipt will be **REJECTED**.

BID OPENING will be held publicly at 2:05 p.m. on February 26, 2008 at 1355 Capital Blvd., Reno, NV 89502.

BID AWARD is scheduled to be made by March 6, 2008.

PRICES must be quoted FOB Sparks, Nevada.

BID DOCUMENTS may be downloaded from TMWA's web site at http://www.tmh2o.com/about_us/doingbusinesswithtmwa/.

QUESTIONS will be accepted until noon on February 20, 2008. All questions must be submitted in writing to Timothy A. Grover, P.E., Truckee Meadows Water Authority, FAX No. 775-834-8003, E-mail: tgrover@tmwa.net.

ADDENDUMS are distributed from TMWA's web site at http://www.tmh2o.com/about_us/doingbusinesswithtmwa/. It is each bidder's responsibility to ensure that they have received all Addendums prior to submission of their bid.

TERM OF CONTRACT: One Time Purchase

Glendale Pump Upgrade Project, Phase 2 – Purchase of Sparks Zone AFD's

TMWA is accepting sealed bids for the purchase of medium-voltage adjustable frequency drives for the Sparks Effluent Pump Station located at the Glendale Water Treatment Facility. Three complete drive systems shall be provided each with the following characteristics:

- Input power: 4160 Volts, 3 Phase, 60 Hz.
- Output: 0 to 4160 Volts, 3 Phase, Pulse Width Modulated waveform suitable for adjustable frequency control of a squirrel cage induction motor.
- Output current: 140A minimum at full load.

Equipment shall be delivered to TMWA's Glendale Treatment Facility for unloading, storage, and installation by others as specified in the Technical Specifications. Installation and startup services shall be provided at the times specified in the Technical Specifications which are different than the time specified for delivery.

Justine Chambers, Purchasing/Contracts Administrator